



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.  
This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

18 Barchester 2025

Certificate No:

## Engineers Details

Trading Title Blue Frog Plumbing and Heating LTD

Address 60 West Drayton Park Avenue  
West Drayton  
Middlesex

Post Code: UB77QB

Gas Safe No: 508237

Telephone No: 07827974485

## Installation Details

Installation Address

Freddie North  
18  
Barchester Close  
Cowley

Post Code: UB8 2JY

Telephone No: +447435967433

## Client Details

Client Address  
Freddie North  
18  
Barchester Close  
Cowley

Post Code: UB82JY

Telephone No: +447435967433

## Appliance Details

	Location	Appliance Type	Make	Model	Combustion LOW (CO2% or CO/CO2 ratio)	Combustion HIGH (CO2% or CO/CO2 ratio)	Heat Input or Operating Pressure (Mbar)	CO Reading (ppm)	Appliance Inspected (YES/NO/NA/0) <small>(0/0 is final inspection only)</small>	Flue Type (OF/RS/FL)	Landlords Appliance (YES/NO/NA)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO/NA)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Central heating boiler	Worcester Bosch	18 Ri	9.3	9.6	18mb mb	70	YES	RS	YES	YES	YES	YES	PASS	YES	YES
2																	
3																	
4																	
5																	

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve  
Accessible:

YES

Gas Tightness Satisfactory:

NA

## Signatures

Gas ID Number: 4929590

Gas Installation Pipework Visual Inspection Satisfactory:

YES

## Report Issued By:

Name: Adam Christian Stone

Signed:

Date: Tue-22-04-2025

Number of Appliances Tested:

1

Equipotential Bonding:

YES

## Report Received By:

Name: Adam Stone

Signed:

Date: Tue-22-04-2025

NEXT INSPECTION DUE ON  
OR BEFORE:

Wed-22-04-2026

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES